



Building Product Evaluation Report 0144

MoistureShield Stratos Deck Boards and Stair Treads Oldcastle

Initial Acceptance: 09 July 2024

Expiration: 09 July 2027

Revision: 02 July 2025

Version: 2.0

TYPE OF ACCEPTANCE

Product Material – Wood and Plastics

CSI Specification Division: 06 50 00 (Structural Plastic) and 06 53 00 (Plastic Decking)

MANUFACTURER IDENTIFICATION:

Oldcastle

400 Perimeter Center Terrace FL 10
Atlanta, GA 30360
1-800-866-8101
www.moistureshield.com

EVALUATION REPORT SUBJECT:

Deck Boards and Stair Treads for Exterior Applications

Installation on construction complying with the International Residential Code® (IRC®), the International Building Code® (IBC®), or with the Florida Building Code® (FBC®)

DESCRIPTION OF BUILDING COMPONENTS:

A. Deck Boards

MoistureShield Inc. deck boards identified as Stratos deck boards are a wood thermoplastic composite lumber product consisting of PVC, glass fiber and wood filler, plus additives and color. The product specifications are listed in the approved quality control manual. Stratos deck board components are manufactured in several colors by the tri-extrusion process with capping covering three sides of the deck board.

1. **Deck Boards:** See attached drawings in **Table 1.A.1**
2. Stratos deck boards can be used as stair treads. When deck boards are used as stair treads, they must be installed perpendicular to the supporting framing. Deck boards and stair treads must be installed over at least two spans. The decking and stair treads must be installed with a minimum gap of 3/16 inch between parallel boards for drainage and decking must be installed with a minimum clearance of 1/8 inch at each end of the board. See manufacturer's installation instructions noted item 4 below.
3. For additional decking installation details see manufacturer's published installation instructions at <https://www.moistureshield.com/support/installation-instructions/>

APPLICABLE CODES:

- 2015, 2018, and 2021 International Building Code® (IBC®)
- 2015, 2018, and 2021 International Residential Code® (IRC®)
- 2020 Florida Building Code (FBS) excluding High-Velocity-Hurricane Zones (HVHZ)



APPLICABLE CHARACTERISTICS REVIEWED:

B. Deck Board(s) – See Table 1 below for a list of the descriptions of the deck boards reviewed.

1. Deck Board: Structural Performance

- (a) The deck boards have been reviewed for uniform load, maximum on-center span, and deck board direction when installed on support framing members. See attached Table 1.
- (b) The deck boards have been reviewed for wind uplift resistance and have an uplift load rating when installed as indicated in Table 1 in this Report.
- (c) The deck boards used as stair treads meet the code-prescribed load requirements including the concentrated load of 300 lbf when installed in accordance with the manufacturer's installation instructions and Table 1 in this Report.
- (d) Review of the structural design for code compliance of supporting members has not been evaluated and is not a part of this Report.

2. Deck Board: Fastening

- (a) The deck boards must be fastened to the structural support members in accordance with the manufacturer's installation instructions and Table 1 of this Report. When manufacturer's installation instructions differ from this Report, this Report governs.
- (b) When deck boards are used as stair treads, they must be installed in accordance with the manufacturer's installation instructions and Table 1 of this Report. When the manufacturer's installation instructions differ from this Report, this Report governs.

3. Deck Board Durability: Temperature

- (a) The deck boards have been reviewed for the temperature range of -20 to 125 °F (-29 to 52 °C).

4. Deck Board Flame Spread Index:

- (a) The flame spread rating for the deck boards described in this Report was between 26-75 when tested with ASTM E84 *Standard Test Method for Surface Burning Characteristics of Building Materials*.

5. Deck Board Decay Resistance:

- (a) The deck boards reviewed for this Report have been deemed comparable to naturally durable wood for resistance to fungal decay.

6. Deck Board Termite Resistance:

- (a) The deck boards reviewed for this Report have been deemed comparable to preservative-treated wood for resistance to termite attack.

7. UV Testing:

- (a) The UV testing was conducted, and an appropriate adjustment factor was applied, in accordance with ASTM D7032 *Standard for Establishing Performance Ratings for Wood-Plastic Composite Deck Boards and Guardrail Systems (Guards or Handrails)*.

APPLICABLE USES:

Stratos deck boards evaluated in this Report are limited to exterior applications for balconies, porches, stair treads, walking surfaces, and decks.

LIMITATIONS OF ACCEPTANCE:

Stratos deck boards described in this Report comply with those codes listed in the Applicable Codes section above and are subject to the following conditions:

1. The deck board products must be limited to Type V-B (IBC) and residential construction in accordance with the IRC for exterior use as deck boards for balconies, porches, decks, and stair treads.
2. Installation of the deck boards must comply with this Report, the manufacturer's published installation instructions (see section A-3 above), and the applicable codes. When deck board manufacturer's installation instructions differ from this Report, this Report governs.



3. The fasteners described in this Report have been evaluated for the installation of the Stratos deck boards only. Compatibility of the fasteners to the treated supporting construction has not been evaluated.
4. Stratos deck boards indicated in this Report must be fastened to the supporting construction as indicated in the manufacturer's installation manual and as outlined in this Report. When deck board manufacturer's fastening instructions differ from this Report, this Report governs.
5. When required, the structural deck board layout must be designed by a professional and submitted to the authority having jurisdiction for final acceptance.
6. Stratos deck boards have not been evaluated as a member of a fire-resistance-rated assembly.
7. MoistureShield, Inc has a third-party inspection program provided by PFS TECO.

DOCUMENTATION SUBMITTED:

Submitted data was provided in accordance with PFS TECO Certification and Inspection Policy: Deck Boards and Guardrails (Quality control manual, Specifications, Manufacturer's installation instructions, test data and descriptive information). The products have been evaluated in accordance with ICC-ES AC174, *Acceptance Criteria for Deck Board Span Ratings and Guardrail Systems (Guards and Handrails)*.



PRODUCT IDENTIFICATION:

Stratos deck boards evaluated in this Report must be identified with a label, stamp, or laser imprint on every deck board, or their packaging. The information that is required is as follows: MoistureShield, Inc, product identification, compliance to ASTM D7032 including the maximum deck board span (inches on center spacing of supports) and loading (psf), the PFS TECO Building Product Evaluation Report number (BPER 0144), and PFS Certification Mark for use in the United States (see image below). Deck boards without this information are not covered under this Report.





Table 1: Span Table and Fastening Schedule for Deck Boards

Nominal Size and Trade Name	Shape	Edge Type	Deck Board Profile	Maximum Span Rating (in/psf) with Deck Board Orientation to Support Joists				Fastening Schedule ¹ and Uplift Values	Maximum Stair Tread Span (in) ¹
				90°	90°	90°	45°		
				100 psf	150 psf	200 psf	100 psf		
1x5.5 Stratos	Solid Profile with Radius Corners	Solid		24" o.c	20" o.c	20" o.c	16" o.c	184 lbf per Starborn Cap-tor #10 x 2-1/2" deck screw using Pro-Plug installation tool	13" o.c.
		Grooved		24" o.c	20" o.c	20" o.c	16" o.c	92 psf with Aegis Clip hidden fastening system 99 psf with MoistureShield Deck Clip hidden fastening System 147 psf with Camo WedgeClip hidden fastening system 82 psf with Camo Edge Deck Screw hidden fastening system	13" o.c.

¹ Deck boards installed with screws must be attached to each joist with two Starborn Cap-tor #10 x 2-1/2" deck screws. Deck boards with side grooves installed with a hidden fastening system (see images below) must be attached to each joist with a fastener according to the manufacturer's installation instructions.

The joists to which the deck boards are attached must have a minimum specific gravity of 0.50 or better (Southern Pine) or the fastening must be designed. Deck boards and stair treads must be installed over at least two (2) spans. Stair treads must be installed perpendicular to supporting members.

No duration of load increase is allowed for the uplift values noted in Table 1 in this Report.




Figure 1. Moistureshield Deck Clip Hidden Fastening System.




Figure 2. Aegis Clip Hidden Fastening System.



Figure 3. CAMO WedgeClip Hidden Fastening System.



Figure 4. CAMO Edge Screw Hidden Fastening System.